



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

**MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION**

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/economy

NOTICE OF ACCEPTANCE (NOA)

Simon Roofing and Sheet Metal Corp. dba SR Products
30505 Bainridge Road, Suite 210
Solon, OH. 44139

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: SR Products Modified Bitumen Roof System Over Wood Decks

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This renews NOA# 12-0517.04 consists of pages 1 through 31.
The submitted documentation was reviewed by Alex Tigera.



NOA No.: 13-0122.11
Expiration Date: 09/13/17
Approval Date: 08/01/13
Page 1 of 31

ROOFING ASSEMBLY APPROVAL

<u>Category:</u>	Roofing
<u>Sub-Category:</u>	Modified Bitumen
<u>Materials</u>	SBS/APP/TPO
<u>Deck Type:</u>	Wood
<u>Maximum Design Pressure</u>	-112.5 psf

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
SR Base 40 PAS	32' 10" x 3' 3-3/8"	ASTM D 6222	Torch applied, polyester reinforced, APP modified bitumen membrane with a burn off polyethylene back face and a smooth or sanded top surface.
SR Base 45 PAM	32' 10" x 3' 3-3/8"	ASTM D 6222	Torch applied, polyester reinforced, APP modified bitumen membrane with a burn off polyethylene back face and a granule top surface and fire retardant chemistry.
SR Base 35 PAS	32' 10" x 3' 3-3/8"	ASTM D 6222	Torch applied, polyester reinforced, APP modified bitumen membrane with a burn off polyethylene back face and a smooth or sanded top surface.
SR Base 40 PAM	32' 10" x 3' 3-3/8"	ASTM D 6222 Type I	Torch applied, polyester reinforced, APP modified bitumen membrane with a burn off polyethylene back face and a granule top surface.
SR Base 30 PSS	32' 10" x 3' 3-3/8"	ASTM D 6164	Torch, hot asphalt or cold adhesive applied, polyester reinforced, SBS modified bitumen membrane with a burn off polyethylene or sanded back face and a polyethylene or sanded top surface.
SR Cap 40 PSM	32' 10" x 3' 3-3/8"	ASTM D 6164	Torch, hot asphalt or cold adhesive applied, polyester reinforced, SBS modified bitumen membrane with a burn off polyethylene or sanded back face and a granule top surface and fire retardant chemistry.
SR Cap 45 PSM	32' 10" x 3' 3-3/8"	ASTM D 6164	Torch, hot asphalt or cold adhesive applied, polyester reinforced, SBS modified bitumen membrane with a burn off polyethylene or sanded back face and a granule top surface and fire retardant chemistry.
SR Base 20 GSS	65' 2" x 3' 3-3/8"	ASTM D 6163 Type I	SBS modified asphalt coated fiberglass reinforced base sheet.
SR SuperiorPly Base	65' 2" x 3' 3-3/8"	ASTM D 6163 Type I	SBS modified asphalt coated fiberglass reinforced base sheet.

APPROVED INSULATIONS:

TABLE 2

<u>Product Name</u>	<u>Product Description</u>	<u>Manufacturer</u> <u>(With Current NOA)</u>
ACFoam-II, ACFoam-III	Polyisocyanurate foam insulation	Atlas Roofing Corporation
High Density Wood Fiberboard	Wood fiber insulation board	Generic
Dens-Deck or Dens Deck Prime	Gypsum insulation board	Georgia Pacific Gypsum LLC
FescoBoard	Rigid perlite roof insulation board.	Johns Manville Corp.
H-Shield	Polyisocyanurate foam insulation	Hunter Panels, LLC
ENRGY 3	Polyisocyanurate foam insulation	Johns Manville Corp.
Multi-Max-3, Multi-Max FA-3	Polyisocyanurate foam insulation	Rmax Operating, LLC
SECUROCK Gypsum-Fiber Board	Fiber reinforced coverboard	United States Gypsum Corporation



APPROVED FASTENERS:**TABLE 3**

<u>Fastener Number</u>	<u>Product Name</u>	<u>Product Description</u>	<u>Dimensions</u>	<u>Manufacturer (With Current NOA)</u>
1.	Dekfast 12, Dekfast 14 & Dekfast 15 HS	Insulation fastener for wood, steel and concrete decks		SFS Intec, Inc.
2.	Dekfast Galvalume Steel Hex Plate	Galvalume hex stress plate.	2 ⁷ / ₈ " x 3 ¹ / ₄ "	SFS Intec, Inc.
3.	Dekfast Dekflat Round Plastic Lock Plate	Polypropylene locking plate.	3" x 3 ¹ / ₄ "	SFS Intec, Inc.
4.	#12 Standard Roofgrip & #14 Roofgrip	Insulation and membrane fastener	Various	OMG, Inc.
5.	Flat Bottom Metal Plate	Galvalume AZ50 stress plate	3" square	OMG, Inc.
6.	OMG Plastic Plate	Polyethylene stress plate	3.2" round	OMG, Inc.
7.	Trufast #14 HD Fastener	Insulation fastener for steel and wood decks		Altenloh, Brinck & Co. U.S., Inc.
8.	Trufast 3" Metal Insulation Plate	Galvalume steel plate	3" round	Altenloh, Brinck & Co. U.S., Inc.

APPROVED SURFACING:**TABLE 4**

<u>Number</u>	<u>Product Name</u>	<u>Product Description</u>	<u>Application Rate</u>	<u>Specification</u>	<u>Manufacturer</u>
1.	SR 60 Non-Fibered Aluminum	Non-fibered aluminum roof coating.	½-1 gal/sq	ASTM D2824 Type I	SR Products
2.	Gravel	To be installed in a flood coat of approved asphalt at 60 lbs/sq	400 lbs/sq	N/A	Generic
3.	Slag	To be installed in a flood coat of approved asphalt at 60 lbs/sq	300 lbs/sq	N/A	Generic

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Name/Report</u>	<u>Report No.</u>	<u>Date</u>
Factory Mutual Research Corporation	4470	J.I. 2W7A7.AM	08.04.94
	4470	J.I. 3001334	02.15.00
	4470	J.I. 3000857	01.12.00
	4470	J.I. 3004091	01.12.00
Underwriters Laboratory	TAS 114	00NK20869	06.08.00
Trintiy ERD	TAS 114	#11751.05.03	05.30.03
	TAS 114	11757.12.00-1	12.01.00
	TAS 114	11757.04.01-1	04.27.01
	TAS 114	#11758.08.03	08.11.03
	TAS 114	#P1738.02.07	02.05.07
	TAS 117(B)-ASTM D6862	C8500SC.11.07	11.30.07
	ASTM D 6164 / D 6222	P10490.08.08	08.14.08
PRI Asphalt Technologies	ASTM D6222	PUSA-062-02-01	12.04.07
	ASTM D6163	PUSA-064-02-02	02.27.08

APPROVED ASSEMBLIES

- Deck Type 1I:** Wood, Insulated
- Deck Description:** $\frac{19}{32}$ " or greater plywood or wood plank, fastened with 8d common nails at 4" o.c. or #8 screws at 6" o.c.
- System Type A(1):** All insulation layers are adhered to a mechanically attached anchor sheet. Membrane is subsequently adhered to insulation.

All General and System limitations apply.

One or more layers of the following:

- Anchor Sheet:** One ply of SR Base 20 GSS or SR SuperiorPly Base Poly Film/Silica Sand, Silica Sand/Silica Sand fastened to the deck as described below:
- Fastening:** Attach base sheet using OMG Roofgrip Fasteners and Flat Bottom Metal Plates spaced 12" o.c. in a 4" lap and 12" o.c. in two equally spaced staggered rows in the center of the sheet.

<u>Base Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Any approved Polyisocyanurate listed in Table 2. Minimum 1" thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck, DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum $\frac{1}{4}$ " thick	N/A	N/A
FescoBoard Minimum $\frac{3}{4}$ " thick	N/A	N/A
Approved High Density Wood Fiberboard Minimum $\frac{1}{2}$ " thick	N/A	N/A

Note: All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

- Ply Sheet:** (Optional) One ply of SR Base 20 GSS, SR SuperiorPly Base, SR Base 30 PSS, SR Base 35 PAS or one or more plies of Type IV or VI ply sheet adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
- Membrane:** One ply of SR Base 40 PAS, SR Base 45 PAM, SR Base 35 PAS, or SR Base 40 PAM torch applied or one ply of SR Cap 40 PSM, or SR Cap 45 PSM torch or hot asphalt applied.



Surfacing: (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

Maximum Design Pressure: -60 psf; (See General Limitation #7)



- Deck Type II:** Wood, Insulated
- Deck Description:** $\frac{19}{32}$ " or greater plywood or wood plank, fastened with 8d common nails at 4" o.c. or #8 screws at 6" o.c.
- System Type A(2):** All insulation layers are adhered to a mechanically attached anchor sheet. Membrane is subsequently adhered to insulation.

All General and System Limitations apply.

One or more layers of the following:

- Anchor Sheet:** One ply of SR Base 20 GAS or ASTM D4601, Type II approved base sheet fastened to the deck as described below:
- Fastening:** Attach base sheet using 11 ga. annular ring shank and 1-5/8" diameter tin caps spaced 8" o.c. in a 4" lap and 8" o.c. in three equally spaced staggered rows in the center of the sheet.

<u>Base Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Any approved Polyisocyanurate listed in Table 2 Minimum 1" thick	N/A	N/A

Note: All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FescoBoard Minimum $\frac{3}{4}$ " thick	N/A	N/A
Approved High Density Wood Fiberboard Minimum $\frac{1}{2}$ " thick	N/A	N/A
DensDeck, DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum $\frac{1}{4}$ " thick	N/A	N/A

Note: Apply top layer of insulation in a full mopping of any approved mopping asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as Base Layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

- Ply Sheet:** (Optional) One ply of SR Base 20 GSS, SR SuperiorPly Base, SR Base 30 PSS or one or more plies of Type IV or VI ply sheet adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.



Membrane: One ply of SR Base 40 PAS, SR Base 45 PAM, SR Base 35 PAS, or SR Base 40 PAM torch applied or one ply of SR Cap 40 PSM, or SR Cap 45 PSM torch or hot asphalt applied.

Surfacing: (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

Maximum Design Pressure: -60 psf; (See General Limitation #7)



Deck Type 1I: Wood, Insulated

Deck Description: $\frac{19}{32}$ " or greater plywood or wood plank.

System Type A(3): All insulation layers are adhered to a mechanically attached anchor sheet. Membrane is subsequently adhered to insulation.

All General and System Limitations apply.

One or more layers of the following:

Anchor Sheet: One ply of SR Base 20 GSS or SR SuperiorPly Base, SR Base 20 GAS or ASTM D4601, Type II approved base sheet fastened to the deck as described below:

Fastening #1: Attach base sheet using 11 ga. annular ring shank and 1-5/8" diameter tin caps spaced 8" o.c. in a 4" lap and 8" o.c. in three equally spaced staggered rows in the center of the sheet.

Fastening #2: Attach base sheet using OMG Roofgrip Fasteners and Flat Bottom Metal Plates, Dekfast 14 with Dekfast Galvalume Steel Hex Plates or Trufast #14 HD Fasteners with Trufast 3" Metal Insulation Plates spaced 12" o.c. in a 4" lap and 12" o.c. in two equally spaced staggered rows in the center of the sheet.

<u>Base Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Any approved Polyisocyanurate listed in Table 2 Minimum 1" thick	N/A	N/A

Note: All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FescoBoard Minimum $\frac{3}{4}$ " thick	N/A	N/A
Approved High Density Wood Fiber Minimum $\frac{1}{2}$ " thick	N/A	N/A
DensDeck, DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum $\frac{1}{4}$ " thick	N/A	N/A

Note: Apply top layer of insulation in a full mopping of any approved mopping asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as Base Layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.



- Ply Sheet:** (Optional) One ply of SR Base 20 GSS, SR SuperiorPly Base, SR Base 30 PSS or one or more plies of Type IV or VI ply sheet adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
- Membrane:** One ply of SR Base 40 PAS, SR Base 45 PAM, SR Base 35 PAS, or SR Base 40 PAM torch applied or one ply of SR Cap 40 PSM, or SR Cap 45 PSM torch or hot asphalt applied.
- Surfacing:** (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.
- Maximum Design Pressure:** -52.5 psf; (See General Limitation #7)



Deck Type 1I: Wood, Insulated

Deck Description: 19/32" or greater plywood or wood plank.

System Type A(4): All insulation layers are adhered to a mechanically attached anchor sheet. Membrane is subsequently adhered to insulation.

All General and System Limitations apply.

Anchor Sheet: One ply of SR Base 20 GSS or SR SuperiorPly Base fastened as below:

Fastening: 12 ga. annular ring shank nails and 1-5/8" tin-caps attached 6" o.c. in 4" lap and 6" o.c. in four equally spaced staggered center rows.

One or more layers of the following:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II, ACFoam-III, H-Shield, H-Shield CG, Multi-Max FA-3, or ENRGY 3 Minimum 1" thick	N/A	N/A
Insulation:	Adhered with Millennium One Step Foamable Adhesive, OlyBond 500, Insta-Stick™ Quik Set Insulation Adhesive or TITESET Roofing Adhesive or 3M Polyurethane Foam Insulation Adhesive CR-20 applied in continuous rows 12" o.c	
Ply Sheet:	(Optional) One ply of SR Base 20 GSS, SR SuperiorPly Base, SR Base 30 PSS or one or more plies of Type IV or VI ply sheet adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.	
Membrane:	One ply of SR Base 40 PAS, SR Base 45 PAM, SR Base 35 PAS, or SR Base 40 PAM torch applied or one ply of SR Cap 40 PSM or SR Cap 45 PSM torch or hot asphalt applied.	
Surfacing:	(Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.	
Maximum Design Pressure:	-60 psf; (See General Limitation #7.)	



- Deck Type 1I:** Wood, Insulated
- Deck Description:** $1\frac{9}{32}$ " or greater plywood or wood plank, fastened with 8d common nails at 4" o.c. or #8 screws at 6" o.c.
- System Type B(1):** Base layer of insulation mechanically fastened, optional top layer adhered with approved asphalt.

All General and System Limitations apply.

One or more layers of the following:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ENRGY 3, H-Shield Minimum 1.5" thick	1 or 7	1:1.33 ft²

Note: Base layer shall be mechanically attached with fasteners and density described. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

<u>Top Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FescoBoard Minimum $\frac{3}{4}$" thick	N/A	N/A
Approved High Density Wood Fiberboard Minimum $\frac{1}{2}$" thick	N/A	N/A

Note: Optional top layer of insulation shall be adhered with approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.

- Base Sheet:** (Optional if using ply sheet in hot asphalt) One or more plies of SR Base 20 GSS or SR SuperiorPly Base adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
- Ply Sheet:** (Optional if using base sheet in hot asphalt) One or more plies of SR Base 35 PAS, SR Base 40 PAS torch applied or one ply of SR Base 20 GSS, SR SuperiorPly Base, SR Base 30 PSS or one to more plies of Type IV or VI ply sheet adhered to the coverboard in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
- Membrane:** One ply of SR Base 40 PAS, SR Base 45 PAM, SR Base 35 PAS, or SR Base 40 PAM torch applied or one ply of SR Cap 40 PSM or SR Cap 45 PSM torch or hot asphalt applied.

Surfacing: (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

Maximum Design Pressure: -60 psf; (See General Limitation #7)



Deck Type 1I: Wood, Insulated
Deck Description: $1\frac{9}{32}$ " or greater plywood or wood plank.
System Type B(2): Base layer of insulation mechanically fastened, optional top layer adhered with approved asphalt.

All General and System Limitations apply.

One or more layers of the following:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ENRGY 3, H-Shield Minimum 1.5" thick	1 or 7	1:1.33 ft²

Note: Base layer shall be mechanically attached with fasteners and density described. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

<u>Top Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FescoBoard Minimum $\frac{3}{4}$" thick	N/A	N/A
Approved High Density Wood Fiberboard Minimum $\frac{1}{2}$" thick	N/A	N/A

Note: Optional top layer of insulation shall be adhered with approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.

Base Sheet: (Optional if using ply sheet in hot asphalt) One or more plies of SR Base 20 GSS or SR SuperiorPly Base adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: (Optional if using base sheet in hot asphalt) One or more plies of SR Base 35 PAS, SR Base 40 PAS torch applied or one ply of SR Base 20 GSS, SR SuperiorPly Base, SR Base 30 PSS or one to more plies of Type IV or VI ply sheet adhered to the insulation in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Membrane: One ply of SR Base 40 PAS, SR Base 45 PAM, SR Base 35 PAS, or SR Base 40 PAM torch applied or one ply of SR Cap 40 PSM or SR Cap 45 PSM torch or hot asphalt applied.

Surfacing: (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

Maximum Design Pressure: -52.5 psf; (See General Limitation #7)



Deck Type 1I: Wood, Insulated
Deck Description: $1\frac{9}{32}$ " or greater plywood or wood plank, fastened with wood screws at 6" o.c.
System Type C(1): All layers of insulation are mechanically attached to roof deck. Membrane is subsequently adhered to insulation.

All General and System Limitations apply.

One or more layers of the following:

<u>Base Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Any approved Polyisocyanurate listed in Table 2 Minimum 1.5" thick	N/A	N/A

Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Approved High Density Wood Fiberboard Minimum $\frac{1}{2}$ " thick	1	1:1.33 ft ²
DensDeck, DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum $\frac{1}{4}$ " thick	1	1:1.33 ft ²

Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: (Optional if using ply sheet in hot asphalt) One or more plies of SR Base 20 GSS or SR SuperiorPly Base adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: (Optional if using base sheet in hot asphalt) One or more plies of SR Base 35 PAS, SR Base 40 PAS torch applied or one ply of SR Base 20 GSS, SR SuperiorPly Base, SR Base 30 PSS or one to more plies of Type IV or VI ply sheet adhered to the coverboard in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Membrane: One ply of SR Base 40 PAS, SR Base 45 PAM, SR Base 35 PAS, or SR Base 40 PAM torch applied or one ply of SR Cap 40 PSM or SR Cap 45 PSM torch or hot asphalt applied.



Surfacing: (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

Maximum Design Pressure: -82.5 psf; (See General Limitation #7)



Deck Type 1I: Wood, Insulated

Deck Description: ¹⁹/₃₂" or greater plywood or wood plank, fastened with 8d common nails at 4" o.c.

System Type C(2): All layers of insulation are mechanically attached to roof deck. Membrane is subsequently adhered to insulation.

All General and System Limitations apply.

One or more layers of the following:

<u>Base Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Any approved Polyisocyanurate listed in Table 2 Minimum 1.5" thick	N/A	N/A

Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Approved High Density Wood Fiberboard Minimum ½" thick	1	1:1.33 ft ²
DensDeck, DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum ¼" thick	1	1:1.33 ft ²

Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: (Optional if using ply sheet in hot asphalt) One or more plies of SR Base 20 GSS or SR SuperiorPly Base adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: (Optional if using base sheet in hot asphalt) One ply of SR Base 35 PAS, SR Base 40 PAS torch applied or one ply of SR Base 20 GSS, SR SuperiorPly Base, SR Base 30 PSS or one to more plies of Type IV or VI ply sheet adhered to the insulation in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Membrane: One ply of SR Base 40 PAS, SR Base 45 PAM, SR Base 35 PAS, or SR Base 40 PAM torch applied or one ply of SR Cap 40 PSM or SR Cap 45 PSM torch or hot asphalt applied.



Surfacing: (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

Maximum Design Pressure: -67.5 psf; (See General Limitation #7)



Deck Type 1I: Wood, Insulated
Deck Description: $\frac{19}{32}$ " or greater plywood or wood plank.
System Type C(3): All layers of insulation are mechanically attached to roof deck. Membrane is subsequently adhered to insulation.

All General and System Limitations apply.

One or more layers of the following:

<u>Base Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Any approved Polyisocyanurate listed in Table 2 Minimum 1.5" thick	N/A	N/A

Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Approved High Density Wood Fiberboard Minimum $\frac{1}{2}$ " thick	1	1:1.33 ft ²
DensDeck, DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum $\frac{1}{4}$ " thick	1	1:1.33 ft ²

Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: (Optional if using ply sheet in hot asphalt) One or more plies of SR Base 20 GSS or SR SuperiorPly Base adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: (Optional if using base sheet in hot asphalt) One or more plies of SR Base 35 PAS, SR Base 40 PAS torch applied or one ply of SR Base 20 GSS, SR SuperiorPly Base, SR Base 30 PSS or one to more plies of Type IV or VI ply sheet adhered to the insulation in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Membrane: One ply of SR Base 40 PAS, SR Base 45 PAM, SR Base 35 PAS, or SR Base 40 PAM torch applied or one ply of SR Cap 40 PSM or SR Cap 45 PSM torch or hot asphalt applied.



Surfacing: (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

Maximum Design Pressure: -52.5 psf; (See General Limitation #7)



Deck Type 1I: Wood, Insulated

Deck Description: $1\frac{9}{32}$ " or greater plywood or wood plank, fastened with 8d common nails at 4" o.c. or #8 screws at 6" o.c.

System Type D(1): All layers of insulation and base sheet mechanically fastened.

All General and System Limitations apply.

One or more layers of the following:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Any approved Polyisocyanurate listed in Table 2 Minimum 1" thick	N/A	N/A
<u>Top Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FescoBoard Minimum $\frac{3}{4}$ " thick	N/A	N/A
Approved High Density Wood Fiberboard Minimum $\frac{1}{2}$ " thick	N/A	N/A
DensDeck, DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum $\frac{1}{4}$ " thick	N/A	N/A

Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Base Sheet: One or more plies of SR Base 20 GSS or SR SuperiorPly Base fastened to the deck as described below:

Fastening: Attach base sheet using OMG Roofgrip Fasteners and Flat Bottom Metal Plates spaced 12" o.c. in a 4" lap and 12" o.c. in two equally spaced staggered rows in the center of the sheet.

Ply Sheet: (Optional) One or more plies of SR Base 40 PAS, SR Base 35 PAS torch applied or one ply of SR Base 20 GSS, SR SuperiorPly Base, SR Base 30 PSS or one or more plies of Type IV or VI ply sheet adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq..

Membrane: One ply of SR Base 40 PAS, SR Base 45 PAM, SR Base 35 PAS, or SR Base 40 PAM torch applied or one ply of SR Cap 40 PSM or SR Cap 45 PSM torch or hot asphalt applied.

Surfacing: (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

Maximum Design

Pressure: -60 psf; (See General limitation #7)



Deck Type 1I: Wood, Insulated
Deck Description: ¹⁹/₃₂" or greater plywood or wood plank.
System Type D(2): All layers of insulation and base sheet mechanically fastened.

All General and System Limitations apply.

One or more layers of the following:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Any approved Polyisocyanurate listed in Table 2 Minimum 1" thick	N/A	N/A
<u>Top Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FescoBoard Minimum ³ / ₄ " thick	N/A	N/A
Approved High Density Wood Fiberboard Minimum ¹ / ₂ " thick	N/A	N/A
DensDeck, DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum ¹ / ₄ " thick	N/A	N/A

Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Base Sheet: One or more plies of SR Base 20 GSS or SR SuperiorPly Base fastened to the deck as described below:

Fastening Attach base sheet using OMG Roofgrip Fasteners and Flat Bottom Metal Plates, Dekfast 14 with Dekfast Galvalume Steel Hex Plates or Trufast #14 HD Fasteners with Trufast 3" Metal Insulation Plates spaced 12" o.c. in a 4" lap and 12" o.c. in two equally spaced staggered rows in the center of the sheet.

Ply Sheet: (Optional) One or more plies of SR Base 40 PAS, SR Base 35 PAS torch applied or one ply of SR Base 20 GSS, SR SuperiorPly Base, SR Base 30 PSS or one or more plies of Type IV or VI ply sheet adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Membrane: One ply of SR Base 40 PAS, SR Base 45 PAM, SR Base 35 PAS, or SR Base 40 PAM torch applied or one ply of SR Cap 40 PSM or SR Cap 45 PSM torch or hot asphalt applied.

Surfacing: (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

Maximum Design Pressure: -52.5 psf; (See General Limitation #7)



- Deck Type 1:** Wood, Non-Insulated
- Deck Description:** $\frac{19}{32}$ " or greater plywood or wood plank, fastened with 8d common nails at 4" o.c. or #8 wood screws at 6" o.c.
- System Type E(1):** Base sheet is mechanically attached to roof deck.
- All General and System Limitations apply.**
- Base Sheet:** One ply of SR Base 20 GSS or SR SuperiorPly Base Poly/Sand, Sand/Sand fastened to the deck as described below:
- Fastening:** Attach base sheet using OMG Roofgrip Fasteners and Flat Bottom Metal Plates spaced 12" o.c. in a 4" lap and 12" o.c. in two equally spaced staggered rows in the center of the sheet.
- Ply Sheet:** (Optional) One or more plies of SR Base 40 PAS, SR Base 35 PAS torch applied or one ply of SR Base 20 GSS, SR SuperiorPly Base, SR Base 30 PSS or one or more plies of Type IV or VI ply sheet adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
- Membrane:** One ply of SR Base 40 PAS, SR Base 45 PAM, SR Base 35 PAS, or SR Base 40 PAM torch applied or one ply of SR Cap 40 PSM or SR Cap 45 PSM torch or hot asphalt applied.
- Surfacing:** (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.
- Maximum Design Pressure:** -60 psf; (See General Limitation #7)



Deck Type 1: Wood, Non-Insulated
Deck Description: ¹¹⁹/₃₂" or greater plywood or wood plank, fastened with 8d common nails at 4" o.c. or #8 wood screws at 6" o.c.
System Type E(2): Base sheet is mechanically attached to roof deck.

All General and System Limitations apply.

Base Sheet: One ply of SR Base 20 GAS, SR Base 20 GSS or ASTM D4601, Type II approved base sheet fastened to the deck as described below:

Fastening: Attach base sheet using 11 ga. annular ring shank and 1-5/8" diameter tin caps spaced 8" o.c. in a 4" lap and 8" o.c. in three equally spaced staggered rows in the center of the sheet.

Ply Sheet: (Optional) One or more plies of SR Base 20 GSS, SR SuperiorPly Base, SR Base 30 PSS or one or more plies of Type IV or VI ply sheet adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Membrane: One ply of SR Base 40 PAS, SR Base 45 PAM, SR Base 35 PAS, or SR Base 40 PAM torch applied or one ply of SR Cap 40 PSM or SR Cap 45 PSM torch or hot asphalt applied.

Surfacing: (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

Maximum Design Pressure: -60 psf; (See General Limitation #7)

Deck Type 1: Wood, Non-Insulated
Deck Description: ¹⁹/₃₂" or greater plywood or wood plank.
System Type E(3): Base sheet is mechanically attached to roof deck.

All General and System Limitations apply.

Base Sheet: One ply of SR Base 20 GAS, SR Base 20 GSS or ASTM D4601, Type II approved base sheet fastened to the deck as described below:

Fastening #1: Attach base sheet using 11 ga. annular ring shank and 1-5/8" diameter tin caps spaced 8" o.c. in a 4" lap and 8" o.c. in three equally spaced staggered rows in the center of the sheet.

Fastening #2: Attach base sheet using OMG Roofgrip Fasteners and Flat Bottom Metal Plates, Dekfast 14 with Dekfast Galvalume Steel Hex Plates or Trufast #14 HD Fasteners with Trufast 3" Metal Insulation Plates spaced 12" o.c. in a 4" lap and 12" o.c. in two equally spaced staggered rows in the center of the sheet.

Ply Sheet: (Optional) One or more plies of SR Base 20 GSS, SR SuperiorPly Base, SR Base 30 PSS or one or more plies of Type IV or VI ply sheet adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Membrane: One ply of SR Base 40 PAS, SR Base 45 PAM, SR Base 35 PAS or SR Base 40 PAM torch applied or one ply of SR Cap 40 PSM or SR Cap 45 PSM torch or hot asphalt applied.

Surfacing: (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

Maximum Design Pressure: -52.5 psf; (See General Limitation #7)

Deck Type 1: Wood, Non-Insulated
Deck Description: $1\frac{9}{32}$ " or greater plywood or wood plank.
System Type E(4): Base sheet is mechanically attached to roof deck.

All General and System Limitations apply.

Base Sheet: One ply of SR Base 20 GSS or SR SuperiorPly Base fastened to the deck as described below:

Fastening: 11 ga. Annular ring shanked nails and 1-5/8" tin-caps 6" o.c. in 4" lap and 6" o.c. in four equally spaced staggered rows. Tin-caps are primed with PG100 primer.

Ply Sheet: (Optional) One or more plies of SR Base 20 GSS, SR SuperiorPly Base, SR Base 30 PSS or one or more plies of Type IV or VI ply sheet adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Membrane: One ply of SR Base 40 PAS, SR Base 45 PAM, SR Base 35 PAS or SR Base 40 PAM torch applied or one ply of SR Cap 40 PSM or SR Cap 45 PSM torch or hot asphalt applied.

Surfacing: (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

Maximum Design Pressure: -112.5 psf; (See General Limitation #7)

WOOD DECK SYSTEM LIMITATIONS:

1. A slip sheet is required with Ply 4 and Ply 6 when used as a mechanically fastened base or anchor sheet.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer.
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.

Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf

5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**

END OF THIS ACCEPTANCE